

Job Name:	
Type:	
Part #:	
Notes:	

# LS500LPTD

# LOW PROFILE FLOURESCENT EMERGENCY BALLAST 500 LUMENS

STANDARD



#### **ILLUMINATION**

- Works with or without an AC ballast to convert new or existing fluorescent fixtures in to unobtrusive emergency lighting.
- Operates one lamp in the emergency mode for a minimum of 90-minutes.
- Provides a maximum initial lumen output of 500 lumens.

#### **ELECTRICAL**

- Universal 120-277V, 50-60 Hz input.
- Charge/Power "ON" LED indicator light and push-to-test switch for mandated code compliance testing.
- 4.8V long life, maintenance-free, rechargeable sealed NiCd batteny
- Internal solid-state transfer switch automatically connects the inter-nal battery to fluorescent lamp for minimum 90-minute emergency illumination.
- Fully automatic solid-state, two rate charger initiates battery charg-ing to recharge a discharged battery in 24 hours.
- Time delay enhancement to overcome end-of-life circuit protection

#### **MOUNTING**

- Suitable for installation inside, on top or in remote\* of the fixture.
- Can be used in both switched and unswitched fixtures.
- UL Listed for factory or field installation.

#### **HOUSING**

- Low profile galvanized steel construction.
- · Compact design fits most fluorescent fixtures.




## **LISTINGS AND WARRANTIES**


- Five year warranty against defects in material and workmanship (lamps excluded).
- Meets UL924, NFPA 101 Life Safety Code, NEC, OSHA, Local and State Codes.
- UL Listed for damp locations (0°C 50°C).
- Suitable for use in sealed and gasketed fixtures.

#### LAMP COMPATIBILITY

- Compatible with most one-, two-, three-, and four-lamp electronic, standard and dimming AC ballasts.
- Operates one T5, T5HO, T8, T12, Circular T5/T9, U-bend T8/ T12 and 4-Pin long CFL lamp in emergency mode. Refer to the chart on the next page for a complete list of compatible lamps.



#### **DIMENSIONS**



Sample Part Number: LS500LPTD

### **ORDERING INFORMATION**

\*When battery packs are remote mounted, the remote distance cannot exceed ½ of the distance from ballast to lamp specified by the A.C. ballast manufacturer. The maximum allowable remote mounting distance is 50 feet.

MODEL	DESCRIPTION
LS500LPTD	500 Lumens Low-Profile Fluorescent Emergency Ballast with Time Delay